



## 2.1 Fire Equipment Signs

500 W. Pennsylvania Ave. \* Southern Pines, NC 28387 \* Phone (910) 692-2720 \* [www.southernpines.net/fire](http://www.southernpines.net/fire)

### Fire Department Connection

- FDC sign shall be 10x14 inch Engineer Grade reflective aluminum with red background, 6-inch-high 1-inch stroke white letters. Building number shall be located at bottom of the sign.



### Fire Sprinkler Bell

- Sprinkler bell sign shall be 10x14 Engineer Grade reflective Aluminum with red background and white letters with facility address mounted just below the bell.  
Example:



**Fire Alarm Control Panel Sign (FACP)**

- FACP sign shall be 10X7 Engineer Grade reflective Aluminum with red background and white letters 6 inch high.



**Fire Riser Room**

- Sign shall be 10x7 Engineer Grade reflective Aluminum with red background and white letters.

