



NOTES:

- 1) ALL SIAMESE CONNECTION'S MUST BE WITHIN 50 FEET OF A FIRE HYDRANT.
- 2) SIAMESE CONNECTION CAN BE ATTACHED TO BUILDING.
CHECK VALVE W/ BALL DRIP NOT REQUIRED IF SIAMESE CONNECTION IS TIED DIRECTLY TO THE BUILDING.
- 3) SIAMESE END CONNECTION SHOULD BE A BRASS PIN PLUG. NOT BREAKABLE CAP.

NOT TO SCALE
DATE: JANUARY 2024

TOWN OF
SOUTHERN PINES

FDC ASSEMBLY DETAIL

W6