



NOTES:

1. 4" - 8" REDUCED PRESSURE DETECTOR ASSEMBLY (RPDA) SHALL BE FEBCO MODEL 825YD OR APPROVED EQUAL.
2. 3/4" - 2" REDUCED PRESSURE ASSEMBLY (RPA) SHALL BE FEBCO MODEL 825Y OR APPROVED EQUAL.
3. SEE SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS OF BACKFLOW PREVENTER, VALVES, ENCLOSURE, ETC.
4. HEATER AND POWER CORD BY G.C., SEE SPECIFICATIONS INSTALL PER MANUFACTURER'S INSTRUCTIONS.
5. RPZ TO BE USC APPROVED.

NOT TO SCALE
DATE: OCTOBER 2020