



## 2.1 FDC & Sprinkler Bell Sign

500 W. Pennsylvania Ave. \* Southern Pines, NC 28387 \* Phone (910) 692-2720 \* [www.southernpines.net/fire](http://www.southernpines.net/fire)

### Fire Department Connection

- FDC sign shall be 9x19 inch Engineering grade reflective aluminum with red background, 6 inch high 1 inch stroke white letters.



### Fire Sprinkler Bell

- Sprinkler bell sign shall be 10x17 .20 reflective Aluminum with red background and white letters with facility address mounted just below the bell.  
See sign examples below.

Example:

