



STANDARD 4' MANHOLE RING AND COVER.
 NOTE: COVER SHOULD BE LABELED WATER
 (SEE DETAIL ?).

FDC

FDC SIGN SHALL BE 9"X19"
 REFLECTIVE GRADE ALUMINUM
 WITH RED BACKGROUND, 6" H
 AND 1" STROKE WHITE LETTERS.

- NOTES:
- 1) ALL SIAMESE CONNECTION'S MUST BE WITHIN 50 FEET OF A FIRE HYDRANT.
 - 2) SIAMESE CONNECTION CAN BE ATTACHED TO BUILDING.
 CHECK VALVE W/ BALL DRIP NOT REQUIRED IF SIAMESE CONNECTION
 IS TIED DIRECTLY TO THE BUILDING.

NOT TO SCALE
 DATE: OCTOBER 2022