



**SPECIAL BEDDING
FOR 11'-20' DEPTHS**

**STANDARD BEDDING
FOR 3' TO 10' DEPTHS**

NOTES:

1. EMBEDMENT MATERIAL MUST BE CLASS I (NO. 67 OR NO. 78M WASHED STONE IS TYPICALLY USED).
2. EMBEDMENT MATERIAL SHALL BE COMPACTED TO A MINIMUM 98% STANDARD PROCTOR DENSITY FOR CLASS I MATERIAL.
3. COMPACTED BACK FILL MUST BE INSTALLED IN 8" LIFTS AND COMPACTED TO 98% STANDARD PROCTOR IN R.O.W. AREAS AND 85% IN NON-R.O.W. AREAS.
4. STANDARD BEDDING SHALL BE UTILIZED FOR ALL CASES WHERE TRENCH BOTTOMS ARE UNSTABLE DUE TO SOIL TYPE, OR MOISTURE CONDITIONS.
5. ALL SANITARY SEWER LINES SHALL BE DESIGNED WITH A DEPTH 10' OR LESS. LINES DEEPER THAN 10' SHALL BE REVIEWED ON A CASE BY CASE BASIS.
6. SUITABLE SOIL MATERIALS ARE DEFINED AS THOSE IN ACCORDANCE WITH AASHTO SOIL CLASSIFICATION GROUPS A-1, A-2-4, A-2-5, AND A-3 (OR IN ACCORDANCE WITH ASTM D2487 SOIL CLASSIFICATION GROUPS GW, GP, GM, SM, SW, SO, SC). SUITABLE MATERIAL SHALL BE FREE FROM ROOTS, ORGANIC MATTER, TRASH, DEBRIS, FROZEN MATERIAL OR STONES LARGER THAN THREE (3) INCHES IN ANY DIMENSION.

NOT TO SCALE
DATE: MARCH 2025